



स्टील अथॉरिटी ऑफ इण्डिया लिमिटेड
STEEL AUTHORITY OF INDIA LIMITED

भिलाई इस्पात संयंत्र
BHILAI STEEL PLANT

Office of the GM (PHE)
Town Engineering Department
Bhilai Steel Plant

No. GM(PHE & PHD))/TSD/2021/08

Bhilai, Date : 25.01.2021

CERTIFICATE

This is to certify that BSP Senior Secondary School, Sector-10, Bhilai is supplied with regular water supply.

The adequate system of purification of drinking water is adopted.

This certificate is issued for the purpose of extension of affiliation of the school, run by Bhilai Steel Plant.

(श्रीमती राधिका श्रीनिवासन)

महाप्रबंधक

(जन स्वास्थ्य अभियांत्रिकी एवं जन स्वास्थ्य विभाग)

Sr. PRINCIPAL
B.S.P. Sr. Sec. School
Sector-10, Bhilai

भिलाई 490 001, छत्तीसगढ़, फ़ैक्स : 0788-2222890, 0788-2223491, ई-मेल : sailbsp@sancharnet.in, वेबसाइट : www.sail.co.in
Bhilai 490 001, Chhattisgarh, Fax : 0788-2222890, 0788-2223491, E-mail : sailbsp@sancharnet.in, Website : www.sail.co.in



**WATER MANAGEMENT DEPARTMENT
BHILAI STEEL PLANT
LABORATORY, WTP, WMD**

01

Dated: 11.01.21

Analysis Report of Drinking Water Sample

Date of Sample -

11.01.21. TSD PHE (West)

Sampling Done By -

Mr. Usha Singh

Sl. No	Parameters	Unit	Norms for Drinking Water	SR Sec. School		Location of Sample				
				Sec 10	Sec 10					
1	Residual Chlorine		Min 0.2 mg/l	0.2						
2	MPN of Coliform Bacteria present in 100 ml of the original sample	ppm	Max Nil	—						
3	Turbidity	NTU	Max 5 NTU	—						
4	Total Suspended Solids	ppm	NA in IS code	—						

- Remarks:-
1. Coliform Bacteria test is done only when residual chlorine is less than 0.2 ppm
 2. Total Suspended Solids test is done only when turbidity is more than 5 NTU
 3. BDL is below detectable level.
 4. Norms are as per BIS 10500 : 1991

[Signature]

SGS. Head WTP, WMD

PGM, TSD

[Signature]
Asstt. Chemist
Laboratory, WTP, WMD

Keep record a copy for records

21/01/21 (PHE-W)

25/1/21



स्टील अथॉरिटी ऑफ इण्डिया लिमिटेड
STEEL AUTHORITY OF INDIA LIMITED
भिलाई इस्पात संयंत्र
BHILAI STEEL PLANT

No. Edn/2021/26


Date : 4.02.2021

CERTIFICATE


BSP Senior Secondary School, Sector-10, Bhilai is maintained in a hygienic sanitary condition.

Sanitary condition is maintained by skilled and adequate number of sanitary workers.

This certificate is issued for the purpose of extension of affiliation of the school, run by Bhilai Steel Plant.


(Mrs Vaishali Supe)

Dy General Manager (Education)
Contract Operating Authority
for Housekeeping & Sanitation of
School Building



Sr. PRINCIPAL
B.S.P. Sr. Sec. School
Sector-10, Bhilai

भिलाई 490 001, छत्तीसगढ़, पिनकोड : 0788-2222890, 0788-2223491, ई-मेल : sailbsp@sancharnet.in, वेबसाइट : www.sail.co.in
Bhilai 490 001, Chhattisgarh, Fax : 0788-2222890, 0788-2223491, E-mail : sailbsp@sancharnet.in, Website : www.sail.co.in